



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-30
7/8
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 657

Dated: 19/08/2025

To

The Principal,
Sarvodaya Kanya Vidyalaya,
Railway Colony, Tughlakabad,
New Delhi-44 (School ID no. 1925046).

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Sarvodaya Kanya Vidyalaya** located at **Railway Colony, Tughlakabad New Delhi-44 (School ID no. 1925046).**

Sir,

With reference to letter bearing outdoor diary no. 4297 dated 30.07.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 08.08.2025 in the presence of Sh. Raj Kumar (Estate Manager) and following shortcomings were observed:-

1. An additional staircase of minimum width of 1.50 meters must be provided in C Block.
2. Hose Reels found non function at each block.
3. Fire pumps found non functional at each block.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.