

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2025/NDZ/School/ 987

Dated: 11.10.2025

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya located at Bulbuli Khana, Asaf Ali Road, New Delhi comprises of 05 block ( A,B,C,D & E ), A block - G+ 3 floors, B, C& E - ground floor , D-Ground & first floor. The FSC was earlier granted FSC by this department vide letter No. F6/DFS/MS/2022/NDZ/School/1099 dated 03/10/2022 & F6/DFS/MS/2022/NDZ/School/579 dated 27/05/2022. Now, the premises was re-inspected by the officers concerned of this department on 21-07-2025 in the presence of Ms. Rehana Umar (HOS) and found that school building blocks as above, have deemed complied with the fire prevention and fire safety requirements in accordance with DFS Rules 2010 is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from .....11.10.2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on .....11.10.2025 at New Delhi by.

  
 (Virendra Singh)  
 Chief Fire Officer  
 Delhi Fire Service

**Copy to:-**

1. The Commissioner , MCD , Civic Centre , New Delhi
2. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.
3. The Principal, Sarvodaya Kanya Vidyalaya at Bulbuli Khana, Asaf Ali Road, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

H/19  
**INSPECTION REPORT**

1. Name & address of the building:- Sarvodaya Kanya Vidyalaya at Bulbuli Khana, Asaf ali Road, New Delhi
2. Type of occupancy:- Educational Group B-I, 05 block ( A,B,C,D & E ), A block - G+ 3<sup>rd</sup> floor, B, C& E - ground floor, D- Ground & first floor
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/2022/NDZ/School/1099 dated 03/10/2022 and No. F6/DFS/MS/2022/NDZ/School/579 dated 27/05/2022
5. Fire safety directives No.- N/A
6. Date of inspection:- 21/07/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Ms. Rehana Umar (HOS)
9. Year of construction:- 1925
10. Applicant's letter No:- letter no.SKV/BBK/2025/230 dated 03.06.2025

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos	Provided	MR
	A block			
	D block	01 no.	Provided	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr	1.7m	MR
	A- block			
	D- block	01 of 1.5m or 02 of any length width	1.5 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor ( new block )	1.5 m	Provided	MR
	F. Door size	1 m ( old ) & 1.20 m( new block )	Provided	MR
3.	Compartmentation			

	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	30 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel ( block- A )			
	1) Total number of each floor	02nos	Provided	MR
	2) Length of hose reel hose	30 mtr	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A

N/21

	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting( new block - A)			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/2022/NDZ/School/1099 dated 03/10/2022 & No. F6/DFS/MS/2022/NDZ/School/579 dated 27/05/2022, under Rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is prepared and put up for kind perusal and signature please.


Signature of the Inspecting Officer




Name :- Ravinder Singh


Designation :- ADO(CC)

 24/7/25


 C.F.O (ms)

 25/07/25

 C.F.O / 29/7/2025

 Principal Director

 C.F.O to D.S.M.

 C.F.O / 25/07/25