

C-60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/ 226

Dated: 16/04/2025

To,

The Principal,  
Sarvodaya Kanaya Vidyalaya No. 2,  
Palam Village, New Delhi- 110045.

**Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanaya Vidyalaya No. 2 (School Code – 1821015) at Palam Village, New Delhi- 110045.**

Sir,

Please refer to your letter No. SKV/No2/PV/2144 dated 10.03.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 01.04.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Tanwar (Estate Manager) was present and it was observed that the school building having 03 blocks namely A Block (G+1 upper floor), B & C Block (G+3 upper floors), and have following shortcomings: -

1. First Aid Hose Reels found provided but found not functional in B & C Block.
3. Terrace fire pump of 450 LPM found provided but found not functional in B & C Block.
5. Exit signages are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.