

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2025/136

Dated: 05/03/2025

To

The Vice Principal,
Sarvodaya Kanya Vidyalaya,
Idgah Road, Delhi-110055.

Sub: Regarding issuing of FSC in r/o Sarvodaya Kanya Vidyalaya, Idgah Road, Delhi-110055.

Sir,

This has reference to your letter no. SKV/IR/2024-25/219 dated 24.01.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 24.02.2025 in the presence of Mis. Mahvish (teacher) and the following shortcomings are observed.

1. Hose reel found non functional and nozzle is also found missing.
2. Pump found non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service
38

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.