



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2025 / School / WZ / 627

Dated 08/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Kanya Vidyalaya No. 1** located at **Keshavpuram, Delhi-110035** is comprised of Ground + Three upper floors owned/ occupied by **Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 3298-3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on **30.04.2025** in the presence of **Smt. Neeru Prabhakar (H.O.S.)** and found that the building/ premises is fit for **occupancy Group B Educational** with effect from **08/05/2025** for a period of **03 (Three) years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on **08/05/2025** at New Delhi by

  
(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Sarvodaya Kanya Vidyalaya No. 1 located at Keshavpuram, Delhi- 110035.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. The electric meter and electrical panel installed inside the corridor have to be removed to a safer place or been segregated within a time period of 3 months from the date of issuance of this fire safety certificate. Failing to do so the fire safety certificate will be null and void.



**INSPECTION REPORT**

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya No.1, Keshavpuram , Delhi- 110035.
2. Type of Occupancy : Educational
3. Building Comprised of : 02 Blocks, Block-1( G+3) & Block-2 (G+ 1 )
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 30/04/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Mrs. Neeru Prabhakar ( Vice Principal)
10. Year of Construction : 1983 as per school performa given
11. Applicant's letter No. : E Mail ID dated 26/04/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	6 m	Provided	MR
	Gate width	4.5 m	Directly Accessible	MR
	Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	Number of staircases			
	Upper Floors	Block 1= 1 Block 2= 1	Block 1= 2 Block 2= 1	MR MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	1.50 m each	Block 1 = 1.30 m × 2 Block 2 = 1.40 m	MR NMR
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	Block 1= 2	Provided	MR
	Width of Corridor	1.5 m	Provided	MR
	Door Size	1 m	1 m, Double Door with door fitting	MR
3.	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Upper floors	Required	Naturally Ventilated	MR
5.	<b>Fire Extinguishers</b>			
	Total numbers	22 Nos.	Provided	MR
	Types	ABC Type	Provided	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	Total numbers on each floor	02	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA



N.31

8.	MOEFA			NA
9.	Public Address System	NA	NA	NA
		NA	NA	
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Ground Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	
11.	Internal Hydrants			NA
	Size of riser/down-comer	NA	100 mm, Provided	NA
	Number of hydrants per floor	NA	02 in each block	NA
	Hose Box	NA	02 in each block	
12.	Yard Hydrants			NA
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	
13.	Pumping Arrangements			
	Ground Level			NA
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA

**Note: Electric meter and electrical panel found installed in the corridor which have to be removed or segregated from the corridor.**

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

 ~~$D_e(f)(\omega)$~~ 

5/5/2015

472 NW  
5/05/25

5/5/2025

15/5/2025

Director

15/5

GSM

~~MS  
GSM  
Ser. 1-7 letter in~~

letter in post by 1/11/19

Joe  
Addison  
6/5/21

~~Director of [illegible] 7/5/20~~