

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/School/SZ/2025/ 1201

Dated: 29/09/2025

FIRE SAFETY CERTIFICATE

Certified that the building of Sarvodaya Kanya Vidyalaya No.-1, C-Block, Janakpuri, New Delhi-110058, having four blocks namely A block comprised of ground plus two upper floors & B, C and D blocks are comprised of ground plus one upper floor each, owned/occupied by Sarvodaya Kanya Vidyalaya No.1, was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/460 dated 26.04.2022. The school building was inspected by the officer concerned of this department on dated 08.09.2025 in the presence of Sh. Rajesh Kumar Gill (Estate Manager) and found that the building/ premises is fit for occupancy class B 'Educational Building' with effect from 29/09/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.
Issued on 29/09/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi.
2. The Principal, Sarvodaya Kanya Vidyalaya No.-1, C-Block, Janakpuri, New Delhi-58.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No.-1, C-Block, Janakpuri, New Delhi.
2. Building comprised of : 4 blocks, Block-A (G+2) & Block-B, C & D (G+1)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/2022/460 dated 26.04.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 20.01.2025
8. Name of Inspecting Officer : A.D.O.R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Rajesh Kumar Gill (Estate Manager)
10. Year of Construction : 1974-75 (G+II Block) & Before 2018 Block-B, C & D
11. Applicant's letter No. : SKV/No.1/C-BLK/JP/EM/2025/419 dated 22.08.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 26.04.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs. 4.5 mtrs N/A	Provided Provided N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	02 No's in Blk-A, 02 no.'s in Blk-B 03 no.'sin Blk-C02 no.'s in Blk-D	04 No's in Blk-A, 02 no. in Blk-B, 03 no.'s in Blk-C & 02 no. in Blk D	MR
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5M/additional staircase of .75M if less than 1.5 M& 1.5 M	1.50 (02 no.'s) & 1.30 (02 no.'s) in Blk-A&1.4 M & 1.5M in Blk-B, 3X 1.5 M in Blk-C&2X1.5 M in Blk D	M/R
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	MR
	e. Width of Corridor	1.50 M	2.40/1.5 M	M/R
	f. Door Size	1.0/1.20 M	.96 & 1.0M in Blk-A, .90 & 1.2 M in Blk-B,C & D (double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	34 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

N/25¹

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor in block A Length of hose reel hose Nozzle diameter 	Two 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm Two Two	Provided Provided Provided	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 2X450 LPM 30 mtrs Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10000 ltrs Required	N/A N/A Provided N/A Provided Provided	N/A N/A N/A N/A M/R M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

(No Lift)

N/26

17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/80 dated 30.01.2025 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2022/460 dated 26.04.2022 is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
22/9/2025
Signature of the Inspecting Officer
Name:-R.K. Yadav
Designation: - ADO (JKP)

DO (SW) *[Signature]*
23/9/25

CFO *[Signature]*
23/9/2025

Principal Director

CFO to D.S. *[Signature]*

[Signature]
22/9/25
CFO *[Signature]*
24/9/2025

ADO (JKP)

PRO