

c 39

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2025/ School/NDZ/946

Dated: 01/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya located at Pandara Road, New Delhi comprised of two block Ground and first floor( old block ) & Ground + 03 Upper floor( SPS type) was earlier granted FSC by this department vide letter No. F6/DFS/MS/2024/School/NDZ/241 dated 27/03/2024 ( Old block ) & No. F6/DFS/MS/2022/School/NDZ/580 dated 27/05/2022. Now, the premises was re-inspected by the officer concerned of this department on 10-07-2025 in the presence of Smt. Vinita Kamberi and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education & DFS Act 2007 & Rules 2010 and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from.....01/08/.....2025 for a period of three years subject to compliance of the conditions mentioned below:

Issued on .....01/08/2025..... at New Delhi by.

  
29/7/2025  
(Virendra Singh)  
Chief fire Officer  
Delhi Fire Service

Copy to:-

1. Director of Education, Old Secretariat, Delhi - 110054.
2. The Principal, Sarvodaya Kanya Vidyalaya at Pandara Road, New Delhi.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.



# INSPECTION REPORT

1. Name & address of the building:- Sarvodaya Kanya Vidyalaya at Pandara Road, New Delhi ( old and new block )
2. Type of occupancy:- Educational Group B-I, Gr. +1 & Gr.+03 Upper Floor
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/2022/School/NDZ/580 dated 27/05/2022 & No. 241 dated 22.03.2024 ( old block )
5. Fire safety directives No.- N/A
6. Date of inspection:- 10/07/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Smt. Vinita Kamberi
9. Year of construction:- 2022 & 1964
10. Applicant's letter No:- No. SKV/PR/2025/172 dated 22/05/2025

There are 02 blocks, one is comprised of ground and first floor and other is new block SPS type comprised of ground and three upper floors.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos. in each block	Provided	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.7 mtr. ( new block ) & 1.5 m( old block)	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	1.5 mtr	1.8 mtr.	MR
	F. Door size	1.20 mtr.	1.20 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A



4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	26 Nos.	28 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each Floor ( New Block )	02 nos.	03 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump( new block )	450 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR

N/25

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 ltr	10000 ltr	MR
	e) ( new block )			
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/2022/School/NDZ/580 dated 27/05/2022 & no.241 dated 22.03.24 ( old block ), under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name: - Ravinder Singh  
Designation: - ADO (CC)

Dn/w  
14/7/25

Dy. C.F.O. (CC)  
C.F.O.

15/07/25

PTD