



No. F6/DFS/MS/School/SZ/2025/ 1255

Dated: 16/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya No.2 located at East of Kailash, New Delhi- 110065, building comprised of New Building Blocks, Ground + 3 upper floors only, owned / occupied by Directorate of Education, Govt. of NCT of Delhi was issued FSC vide letter No. F6/DFS/MS/School/2022/SZ/1042 dated 20/09/2022. The school building was re-inspected by the officer concerned of this department on 08/10/2025 in presence of Mrs. Sudesh Rani (Principal) of the school building is fit for occupancy class "Educational Building" (Group - B) with effect from 16/10/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 16/10/2025 at New Delhi by.


(A.K. Malik)
Dy Chief Fire Officer
o/c Delhi Fire Service
(u)

Copy to: -

1. The Assistant Engineer (E) Edu. Maint. Sub-div- MI, PWD, Hauz Khas, New Delhi-110016.
2. The Director of Education, Govt. of NCT of Delhi, old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Sarvodaya Kanya Vidyalaya- No.2 located at East of Kailash, New Delhi-110065.		
02.	Building is comprised of	New Building Blocks, Ground + 3 upper floors		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal.		
05.	Details of previous FSC	F6/DFS/MS/School/2022/SZ/1042 dated 20/09/2022		
06.	Fire safety directives letter no.	NBC/UBBL- 2016		
07.	Date of inspection	08.10.2025.		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (BCP)		
09.	Name of the designation of officer from the building side	Mrs. Sudesh Rani (Principal)		
10.	Year of construction	2022		
11.	Applicant's letter no.	Email dated 19/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	UBBL-2016 Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	Required	09 mtrs	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	04 nos.	04 nos	MR
	C Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs	1.50 mtrs. each	MR
	C Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	04 nos	Provided	MR
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.2 mtr.	1.2 mtr.	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A
05.	Fire Extinguisher:			
	A Total numbers	54 nos.	70 nos.	MR
	B Types	ABC/CO ₂	ABC/CO ₂	MR
	C ISI marking	ISI Marked	ISI Marked	MR

Sarvodaya Kanya Vidyalaya No.2 located at East of Hanuman

06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	04 at each	Provided	MR
	B	Length of hose reel hose	30 mm	Provided	MR
	C	Nozzle diameter	05 m	Provided	MR
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	MOEFA:				N/A
09	Public Address System:				N/A
10.	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12.	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM x 2	Provided	MR
	B	Head of the pump	40 m	Provided	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	10,000 ltrs each	Provided	MR

15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
	A Pressurization of lift shaft	N/A	N/A	N/A
	B Pressurization of lift lobby	N/A	N/A	N/A
	C Communication in lift car	N/A	N/A	N/A
	D Firemen's grounding switch	N/A	N/A	N/A
	E Lift signage	N/A	N/A	N/A
17.	Standby Power Supply:			
18.	Refuge Area:			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19.	Fire Control Room:			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:	NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/SZ/1042 dated 20/09/2022 under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/BCP

DO/SD

Principal Director

Spoken with DO(SD), The performance is of G+3 building & identical.

14/10/25

2) - Contd -

14/10/25
MALIK