

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/WZ/2025/223

Dated: 10/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidhyalaya, Nithari, Delhi-110086, (School ID-1412093)** comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2022/283 dated 14.02.2022**. The premises was re-inspected by the officer concerned of this department on **20.02.2025** in the presence of **Mrs. Monika (In-charge)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 10/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 10/03/2025 at New Delhi by

(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, Sarvodaya Kanya Vidhyalaya, Nithari, Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

Name & address of the building	: Sarvodaya Kanya Vidhyalaya, Nithari, Delhi-110086.(School ID-1412093)
2. Type of Occupancy	: Educational
3. Type of Case	: Renewal (Ground + 3 upper floors)
4. Details of Previous NOC	: F.6/DFS/MS/School/WZ/2022/283 dated 14.02.2022
5. Fire Safety directives letter No	: NBC Part-IV
6. Date of inspection	: 20.02.2025
7. Name of Inspecting Officer	: A.K.Sharma ADO(Rohini)
8. Name and designation of officers	
From the building side	: Mrs. Monika (In-charge)
9. Year of Construction	: 2021
10. Applicant's letter No.	: Online e-mail dated 28.10.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	Provided	MR
	• Gate width	4.5m	5.8m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	06nos.	06 + 01 ramp	MR
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases			
	• Upper Floor	1.5m	1.60m	MR
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	06nos.	06nos.	MR
	e. Width of Corridor	1.5m	1.8m	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	60nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• ISI marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	06nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-

N/22

Special Protection
According to

	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450lpm	2 x 450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	20,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	NA	-NA-	-NA-

2/2

N/23

-NA	Special Fire Protection System for Protection of special Risks, if any:	NA	-NA-	-NA-
-----	---	----	------	------

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/School/WZ/2022/283** dated **14.02.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature 21/2/25

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Received on 3/3/2025

DO (NW)-On leave

Dy. CFO (WZ)

Please check & forward this file as you have joined duty.
3/3/2025

DO (NW)

Signature
04/03/2025

Dy CFO (WZ)

Signature
5/3/2025

Signature
6/3/2025

Director
Signature
6/3/25

Signature

Fi letter is put up for kind perusal and signature please.

Director
Signature

Signature
7/3/25

DOFO/.../1004/NAW
Date... 5/3/2025