

231

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/141

Dated: 07/03/2025

To,

The Principal,
Sarvodaya Kanaya Vidyalaya No. 1,
Sagarpur, New Delhi- 110046.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanaya Vidyalaya No. 1 at Sagarpur, New Delhi- 110046.

Sir,

Please refer to your letter dated 09.12.2024, received from online email Id sagarpur.131@gmail.com, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 21.02.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Pritam Singh (Manager) was present and it was observed that the school is running at ground plus two upper school in a building comprised of ground plus three upper floors (3rd floor used for owner residence), and have following shortcomings: -

1. Width of two doors of MP Hall to be increased to 2.0 m each.
2. Hose reels found provided but not functional.
3. Terrace fire pump of 450 LPM found provided but not functional in auto mode.
5. Exit signages are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.