



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/142

Dated: 07/03/25

To,

The Principal,  
Sarvodaya Kanya Vidyalaya,  
Rajouri Garden Main,  
New Delhi – 110027.

Sub: Inspection report in r/o. Sarvodaya Kanya Vidyalaya, Located at Rajouri Garden Main, New Delhi – 110027. (School ID-1515022)

Sir,

With reference to your Email dated 17/01/2025, received through diary no. 559 dated 17/01/2025 of this department, on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 22/02/2025, in the presence of Smt. Mamata Oberoi (H. O. S.) to see the functioning of the fire safety arrangements/equipment's provided in the building.

During inspection, it has been observed that the said school building is comprised of Ground + 02 Upper Floor (old building), Fire Safety Arrangements such as, Fire Extinguishers, First Aid Hose Reels, Terrace pump, etc. are provided. However, following shortcomings were observed: -

1. First Aid Hose Reel is provided but not functional.
2. Terrace fire pump of 450lpm provided but not functional.
3. Exit signage's are found removed at some places.

In view of above shortcomings, the application for renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Copy To:-

1. The Directorate of Education Old Secretariat Delhi – 110054.

11C  
JJP  
05/3/2025