

C-56



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2026/ 162

Dated:- 09/10/2026

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya No.- 3 (M. Blk & P. Blk), Tilak Nagar, New Delhi- 110018, comprised of Main Block- Ground + 03 Upper floors & Pry Block- Ground + 01 Upper floor, owned/occupied by Sarvodaya Kanya Vidyalaya No.- 3 have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 17/09/2026 in the presence of Ms. Renu Sethi (Principal) and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 09/10/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 09/10/2026 at New Delhi by

[Signature]
 21/10/26

A.K. Malik
 Chief Fire Officer

[Signature]
 08/10/26

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Sarvodaya Kanya Vidyalaya No.- 3, Tilak Nagar, New Delhi- 110018.

Conditions for validity of fire safety certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Kanya Vidyalaya No.- 3, Tilak Nagar, New Delhi- 110018 (M. Blk & P. Blk)		
2.	Type of Occupancy	Educational Building (Group-B)		
3.	Building comprised of	Main Block- Ground + 03 Upper floors Pry Block- Ground + 01 Upper floor		
4.	Type of Case	New		
5.	Details of previous NOC	Nil		
6.	Fire Safety directives letter No	D.O.E Circular 3298-3398 dated 01/03/2011		
7.	Date of inspection	17/09/2026		
8.	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JKP)		
9.	Name and designation of officers from the building side	Ms. Renu Sethi (Principal)		
10.	Year of Construction	1984 (M. Blk), 2010 (P. Blk)		
11.	Applicant's letter no.	SKV-3/TN/2026 dated 10.06.2026		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular Dt. 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible 6.0 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Main Blk- 02 Pry. Blk- 02	Main Blk- 02 Pry. Blk- 02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m/0.75 m if less than 1.50 m	Main Blk- 1.50 m, 1.48 m Pry. Blk- 1.54 m (Iron), 1.40 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	MB- 2.0 m, PB- 1.75 m	MR
	f. Door Size	1.0 m	MB- 1.10 (Double door) & PB- 1.10 m (Double door)	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	16 nos.	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

Required in Main Block (G+3)				
6	First-Aid Hose Reels.			
	- Total numbers on each floor - Length of hose reel hose - Nozzle diameter	02 nos.	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	- Type of detectors - Location of Main Panel - Location of Repeater Panel - Alternate source of power - Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	- Basement at some location - Upper Floor - Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	- Size of riser/down-comer - Number of hydrants per floor - Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	- Total number of hydrants - Hose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	- Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access - Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump	Required in Main Block (G+3)		
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required in Main Block (G+3)		
		450 lpm	450 LPM x 2 nos.	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	- Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank - Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.			
		Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building/premises (Main & Pry. Block) were checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/School/2018/SZ/2156 dated 18/5/2018 (C/22) in r/o Main & Primary Block, found rectified.

Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures as required under the rules and it is **recommended** to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared & put up for approval please.

* Delay submission of this file is regretted as file was inadvertently mingled with record's file.

Aman Kumar Lathar
ADO (JKP)

DD (S/W)

18/9/26

DFS (WZ)

Cfo (WZ)

23/09/2026

Debabrata Mukherjee

24/9/26
A.K. MALIK

re. Mr.

Cfo (WZ)

When did we receive applⁿ?
2019