



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/599

Dated: 15/07/2025

To

The Principal,
Sarvodaya Co-Ed. Vidyalaya,
Mehram Nagar, New Delhi-110037

Sub: Renewal of Fire Safety Certificate in r/o Sarvodaya (Co-Ed.) Vidyalaya, Mehram Nagar, New Delhi-110037 (School ID: 1720003)

Sir,

This has a reference to your letter No. MN/2025-26/255 dated 20/05/2025 received in this department vide outdoor diary No. 1937 dated 21/05/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 30/06/2025 from fire safety point of view, in your presence. During course of inspection, the shortcomings observed are as below.

1. The hose-reel hose found non-functional, shut-off nozzle missing.
2. Terrace level fire pump found non-functional.
3. Overhead water storage tank exclusive for firefighting found empty.
4. Exit signage found removed at some locations.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)

DIRECTOR

Ph: 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.