



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/125

Dated: 24/02/2025

To

The Head of School,  
Sarvodaya Vidyalaya,  
Jor Bagh, New Delhi-110003

**Sub: Request for renewal of Fire Safety Certificate in r/o Sarvodaya Vidyalaya (New Bldg., SPS Shed), Jor Bagh, New Delhi-110003 (School ID: 2026005)**

Sir,

This has a reference to your email received from Id. [svjb@gmail.com](mailto:svjb@gmail.com) dated 03/01/2025, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on dated 14/02/2025 in the presence of Sh. Ram Prasad (Estate Manager). During course of inspection, the shortcomings observed are as below.

1. The hose-reel provided but non-functional, nozzle missing.
2. Terrace level fire pump provided but non-functional.
3. Exit signage found removed from some locations in escape route.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings above, under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
Director

T. No. 011-23414000  
01/02

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.