

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE**  
**CONNAUGHT PLACE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 868

Dated: 04/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Sarvodaya Vidyalaya** (New Building SPS Shed) located at Jor Bagh, New Delhi-110003 (School ID: 2026005), comprised of Ground + 03 upper floors, owned/occupied by Directorate of Education, Govt. of NCT of Delhi, was issued FSC by this department vide letter No. F.6/DFS/MS/2022/SZ/School/14 dated 05/01/2022. The premises was re-inspected by the officer concerned of this department on dated 26/06/2025 in the presence of Sh. Satish Kr. Yadav (Principal) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premise is fit for occupancy class "**Educational Group B**" (School) with effect from 04/07/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/07/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

act

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, Sarvodaya Vidyalaya (School ID: 2026005), Jor Bagh, New Delhi-110003

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



N-24

## INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Vidyalaya located at Jor Bagh, (New Building), New Delhi-110003 (School ID: 2026005)		
2.	Type of occupancy	Educational, Group-B (School)		
3.	Building comprised of	Ground + 03 Upper Floors (SPS Shed)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/2022/SZ/School/14 Dt. 05/01/2022		
6.	Fire Safety directives letter No.	NBC (Part-IV)		
7.	Date of Inspection	26/06/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side.	Sh. Satish Kr. Yadav (Principal)		
10.	Year of construction	2020		
11.	Applicant's letter No.	Received through email dated 17/06/2025 mail Id. <a href="mailto:svjb14@gmail.com">svjb14@gmail.com</a>		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	02 Nos	04 Nos	MR
	➤ Basements	NA	NA	NA
	b. Width of staircases			
	➤ Upper floors	1.5 mtr	1.80m x 4	MR
	➤ Basements	NA	NA	NA
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	One	Four	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1.10m x 2	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers at each floor	10 Nos	20 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	2 Nos	Provided 03 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR



7.	Automatic fire detection and alarming system	NA	NA	NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System			
10.	Automatic Sprinkler System	NA	NA	NA
	• Basements	NA	NA	NA
	• Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• <b>Ground Level</b>			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• <b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 Ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
		Required	Provided	MR
17.	Standby Power Supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N-26

19.	Fire Control Room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings communicated vide letter No. F.6/DFS/MS/School/2025/SZ/125 dated 24/02/2025 found rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/2022/SZ/School/14 dated 05/01/2022, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal & approval please.

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

cto / 01/07/2025

Director

Sir, FT letter is put up for your sig. pl

Director / 02/07/25

02/07/25