

e 43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 1121

Dated: 09/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Vidyalaya located at Mansarovar Garden, New Delhi-110015. (School ID-1516003), said school is running in total two blocks comprised of (ground + 01, ground + 02 upper floors), was issued FSC vide letter no. F6/DFS/MS/WZ/School/2022/910 dated 18/08/2022. The school building/premises was re-inspected by the officer concerned of this department on 25/08/2025 in the presence of M/s. Sangeeta Thareja (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have deemed complied with fire prevention and fire safety requirements in accordance with D. O. E. Circular No. 3298-3398 dated 01/03/2011/NBC Part -IV and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 09/09/2025 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions mentioned below under Rule 38 of the DFS Rule, 2010 .

Issued on 09/09/2025 at New Delhi.


8/9/2025
Virendra Singh
Chief Fire Officer

Copy to:

1. The Principal, Sarvodaya Vidyalaya located at Mansarovar Garden, New Delhi-110015. Email viceprincipal.svmg@gmail.com
 2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
- Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Vidyalaya located at Mansarovar Garden, New Delhi-110015. (School ID-1516003)
2.	Type of Occupancy	Educational Two Blocks (Ground + 01, Ground + 02 upper floors)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/WZ/School/2022/910 dated 18/08/2022
5.	Fire Safety directives letter No	D.O.E. Circular No. 3298-3398 dated 01/03/2011
6.	Date of inspection	25/08/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	M/s. Sangeeta Thareja (Principal)
9.	Year of Construction	1985 (As per previous Inspection Report dtd. 10/08/2022)
10.	Applicant's letter No.	Email dated 07/08/2025

The said school is running in total two blocks (ground + 01, ground + 02 upper floors), was issued FSC vide letter no. F6/DFS/MS/WZ/School/2022/910 dated 18/08/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mts 5 mts N/A	Provided Provided N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 in each block N/A	02 Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 mts each N/A	G +2 = 2 x 1.35m G + 1 = 1.33m & 1.20m N/A	MR (Old case) N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	16 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30mtr 05mm	Provided Provided Provided	MR MR MR


7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	2 X 450 LPM Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

W/23

19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were checked and found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/School/2022/910 dated 18/08/2022, **renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.**


 Signature of the Inspecting Officer
 Sarabjeet Singh ADO (MN)


304/ADO/MN
27/08/25

Dy.CFO (WZ)


28/8

CFO/
2/9/2025


Principal Director

CFO to Sessne.

02/09/25

CFO 

ADO (MN)

Sir, F&T is put up for your kind perusal & signature please.

CFO/
8/9/2025


04/9/25

MS

DCFO/... 2022/462
Dated 22/9/2022