



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

248




No. F6/DFS/MS/School/WZ/2025/ 1110

Dated: 08 / 09 / 2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Vidyalaya (Sarvodaya Co. Edu. senior secondary school) located at east Punjabi Bagh, New Delhi-110026, (School ID-1515004), comprised of 02 blocks (ground + 01 upper floor each), was issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/954 dated 05/09/2022. The premises was re-inspected by the officer concerned by this department on 14/08/2025 in the presence of M/s. Dr. Sadhana Aggarwal (Principal) and found that the said school building deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education Govt of NCT of Delhi, and that the building/premises is fit for the occupancy class "Educational" Group B with effect from ...08/09/2025 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS rules, 2010 conditions mentioned below:-

Issued on ...08/09/2025 at New Delhi.


6/9/2025
Virendra Singh
Chief Fire Officer

Copy to:

1. The Principal, Sarvodaya Vidyalaya (Sarvodaya Co. Edu. Senior Secondary School) (ID-1515004) located at East Punjabi Bagh, New Delhi-110026. Email ID-1515004z15@gmail.com
2. The Director, Directorate of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. The upper floor in Block- 2, having one staircase strictly shall not be used for school activity.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Vidyalaya (Sarvodaya Co. Edu. Senior Secondary School), Located at East Punjabi Bagh, New Delhi-110026. (School ID-1515004)
2.	Type of Occupancy	Educational 02 Block (ground + 01 upper floor each)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/954 dated 05/09/2022
5.	Fire Safety directives letter No	3298-3398 dated 01/03/2011
6.	Date of inspection	14/08/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	M/s. Dr. Sadhana Aggarwal (Principal)
9.	Year of Construction	2017 As per prev. insp. report dated 16/08/2022
10.	Applicant's letter No.	

The said school is running in total two blocks, both are comprised of ground + 01 upper floor only, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/954 dated 05/09/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Old BLK-2 = 1.55m Old BLK-1 = 1.56m & 1.55m	MR old case
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	2 X 1.0 m	Provided	MR(Old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR


6	First-Aid Hose Reels.	NA	NA	NA
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.	NA	NA	NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts			

N/32


	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the F.S.C issued vide letter no. F6/DFS/MS/School/WZ/2022/954 dated 05/09/2022, renewal under DOE Circular no. 3298-3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.


 Signature of the Inspecting officer
 Name: - Sarabjeet Singh
 Designation: - ADO (MN)

308/ADO/MN
19/08/2025


19/8/2025

CB/
22/8/2025

Principal Director

CFD to Bscue.

28/8/25

ADO (MN)


CFD

Sir, F.T is put up for your kind personal & signature p/s.

C.R.O.

01/9/2025

MS


04/9/25

DCFOI... 20.8.2025
Dated... 19/8/2025