

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 580

Dated: 01/05/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Kanya Vidyalaya No.1** at Sagarpur, New Delhi -110046, is having Six Blocks i.e. A & B block ground plus one & C, D & F block ground plus two upper floors & E block (MP Hall) ground floor only. Owned/occupied by Sarvodaya Kanya Vidyalaya No.1 was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2022/SZ/606 dated 01.06.2022. The School building was re- inspected by the officer concerned of this department on 30.04.2025 in the presence of Dr. Geeta (Principal) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**Except MP Hall**) is fit for occupancy class "**Educational Building**" w.e.f. 01/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 01/05/2025 at New Delhi by.

(Atul Garg)
 Director
 Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Sarvodaya Kanya Vidyalaya No.1 at Sagarpur, New Delhi -110046

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No.-1, Sagarpur, New Delhi-110046.
2. Building comprised of : 6 blocks namely A & B Block (G+1), C, D & F Block (G+2), & E block is having ground floor only (i.e. MP Hall).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/606 dated 01.06.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 30.04.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Dr. Geeta (Principal)
10. Year of Construction : GF Blk-1985, Admn. Blk-2011 & 2016-17
11. Applicant's letter No. : SKV/SP/1/2025/3271 dated 30.04.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 01.06.2022 & UBBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	06 mtrs 4.7 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	02 No.'s in A, B & F blk & 03 no.'s in C blk & D blk	02 No.'s in A, B & F blk & 03 no.'s in C & D blk	M/R
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5 m & .75 m	1.59 & 1.52 m in A Blk, 1.85 m & .75 in B blk, 1.5, 1.75 & 1.80 m in C blk, 1.55 m (03 no.'s) in D blk & 2X 1.50 m & 1X1.5 (02 no.'s) in F blk,	M/R
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One/Two	M/R
		1.5 m	2.07/1.75 m	M/R
	e. Width of Corridor	1.0 m in A, B, C, D & F block & 2.00 m in E block (i.e. MP Hall)	1.0 m (double doors) in B & C blk, 1.10 m (double doors) in D blk, 1.00 & 1.10 m in F blk & 1.65 m (03 no.'s) in E blk	M/R in A, B, C, D & F blk & NMR in E blk (i.e. MP hall)
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	36 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			Provided	M/R

129

16.

6.	First-Aid Hose Reels			Provided	M/R
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	Required in C, D & F blocks 30 mtrs 5 mm		Provided	M/R
				Provided	M/R
7.	Automatic fire detection and alarming system				N/A
	<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters' Location	N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
8.	MOEFA	N/A	N/A		N/A
9.	Public Address System	N/A	N/A		N/A
10.	Automatic Sprinkler System				N/A
	<ul style="list-style-type: none">BasementGround FloorSprinkler above false ceiling	N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
11.	Internal Hydrants				N/A
	<ul style="list-style-type: none">Size of riser/down-comerNumber of hydrants per floorHose Box	N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
12.	Yard Hydrants				N/A
	<ul style="list-style-type: none">Total number of hydrantsHose Box	N/A	N/A		N/A
		N/A	N/A		N/A
13.	Pumping Arrangements				N/A
	<ul style="list-style-type: none">Ground Level<ul style="list-style-type: none">Discharge of main PumpHead of Main pumpNumber of main pumpsJockey Pump out putJockey pump headStandby Pump out putStandby Pump HeadAuto Starting/Manual Stopping	N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	N/A		N/A
	<ul style="list-style-type: none">Pump House AccessTerrace level<ul style="list-style-type: none">Discharge of pumpHead of the pumpPower SupplyAuto Starting of pump	N/A	N/A		N/A
		450 LPM in C, D & F blocks	Provided		M/R
		40 mtrs	Provided		M/R
		Required	Provided		M/R
		Required	Provided		M/R
14.	Captive Water Storage for fire fighting				N/A
	<ul style="list-style-type: none">Underground tank capacity<ul style="list-style-type: none">Draw-off connectionFire service inletAccess to tankOverhead Tank capacity	N/A	N/A		N/A
		N/A	N/A		N/A
		N/A	Provided		N/A
		N/A	N/A		N/A
		10,000 ltrs in C, D & F blocks	Provided		M/R
15.	Exit Signage.	Required	Provided		M/R


W/28

Provision of Lifts.		No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/606 dated 01.06.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.


Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~DO (SW)~~


26/4/25

C.F.S. / 01/05/2025

Director
11/5/25
