



C118




No.F6/DFS/MS/2025/GH/ 112

Dated 05/03/2025

FIRE SAFETY CERTIFICATE

Certified that the M/S Satyam Guest House located at 5134-35, Main Bazar, Pahar Ganj, New Delhi comprised of Ground + 03 Upper floors, Ground floor (Reception + 08 guest house), 1<sup>st</sup> floor (10 guest rooms), 2<sup>nd</sup> floor (11 guest rooms) and 3<sup>rd</sup> floor (10 guest rooms), total 39 guest rooms owned/occupied by M/S Satyam Guest House granted FSC by this department vide letter F6/DFS/MS/GH/NDZ/2022/172 dated 30.03.2022. Now, the premises was re-inspected by the officer concerned of this department on 24.02.2025 in the presence of Sh. Nipun Arora (Owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 Ground floor (Reception + 08 guest house), 1<sup>st</sup> floor (10 guest rooms), 2<sup>nd</sup> floor (11 guest rooms) and 3<sup>rd</sup> floor (10 guest rooms) Total -39 guest rooms only with effect from ....05/03/2025 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...05/03/2025...at New Delhi by.

  
(Atul Gang)  
Director  
Ph: 011-23414000  
9c G

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, to ensure the occupancy detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defense Colony New Delhi. ID no. 2025021301838 dated 13.02.2025.
3. The Owner, M/s Satyam Guest House at 5134-35, Main Bazar, Pahar Ganj, New Delhi.

Conditions for the validity of Fire safety certificate

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MHA portal along with a copy of this Certificate, six months prior to its expiry".

N/38

### INSPECTION REPORT

1. Name & address of the building M/s Satyam Guest House at 5134-35, Main Bazar, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1  
Gr. + 03 Upper floors (total 39 Guest rooms)  
Ground floor (Reception + 08 guest house), 1<sup>st</sup> floor (10 guest rooms + office + store), 2<sup>nd</sup> floor (11 guest rooms + store) and 3<sup>rd</sup> floor (10 guest rooms)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/GH/NDZ/2022/172 dated 30.03.2022
5. Fire safety directives No.- N/A
6. Date of inspection:- 24.02.2025
7. Name of the inspecting officer:- ADO (RN)
8. Name & designation of officer  
From the building side:- Sh. Nipun Arora (Owner)
9. Year of construction:- 1987
10. Applicant's letter No:- ID No. 2024040804457 dated 14.02.2025  
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	01 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	0.80 mtr.	0.94 & 1.26mtr.	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	NA	N/A	N/A
	2) Upper floors	Required	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

N/39				
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Gr. floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. floor	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR

18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

Note:-

The compliance of the provision contained as per gazette notification no. F.5(189)/AD/LB/2016/4053-67 dated 27.05.2019 has been complied.

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. No. No F6/DFS/MS/GH/NDZ/2022/172 dated 30.03.2022, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

*(Signature)*

25/02/2025

Signature of the Inspecting Officer  
Name: - C.L. Meena  
Designation: - ADO (RN)

DO/CC

*26/2/25*

*Dy. C.F.O. (1002)*

*24/02/25*

*C.F.O.*

*28/2/2025*

*Director*

*Director*

*ADDO RN*

As approved, F.T. letter is put up for your signature re.

*(Signature)*

03/03/2025  
ADDO (RN)

*M*

*05/03/25*