

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2025/ 31 To,

Dated: 20/01/2025

Dr. Saurabh Kumar (Head of Office), SRHC Hospital, Narela, Delhi-110040.

Sub: - Inspection report in r/o M/s. Satyawadi Raja Harishchandra Hospital, Plot No. 30, Sec. 7 A, Narela, Delhi- 110040.

Sir,

This is in reference to your e mail id dated 27/12/2024 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned by this department on 15/01/2025 in the presence of Sh. Rakesh Kumar Meena (J.E., Electrical) & Sh. Saurabh (J.E., Civil) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/WZ/2024/418 dated 24/07/2024. During the course of inspection it was observed that fire fighting systems like pumping system, first aid hose reels, internal hydrants, yard hydrants, MOEFA, P.A. system etc. found functional but some shortcomings are still not rectified. The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	Internal Road of 6 m found obstructed by new construction.	Not Rectified
2.	Door closers of fire check doors found removed.	Rectified
3.	Fire check door in basement found broken.	Not Rectified
4.	MOEFA found provided but not functional.	Rectified
5 .	Hose boxes found without hose pipes.	Rectified
6.	Pumping system not found in auto mode.	Rectified
7.	Fire control room and patient registration room shall be separate.	Not Rectified

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall is at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

Ph. 011-23414000

Copy to:-

- 1. The Executive Engineer, PWD (Electrical), HMED, North Dr. BSA Hospital, Sec. 6, Rohini, Delhi-110085.
- 2. Dr. Rakesh Kartar Ahuja (State Program Officer, QA), State Program Management Unit, Delhi State Health Mission, 6th floor, A & B Wing, Vikas Bhawan-II, Civil Lines, Delhi- 110054.