




FIRE SAFETY CERTIFICATE

Certified that the The Saviour's School located at B - 106 (New No.872), New Ashok Nagar, Delhi - 110096, building comprised of Basement (Store), Ground plus three upper floors, Terrace floor - 03 room SPS (Sealed and Not in use) owned/occupied by The Saviour's School was issued FSC vide letter No. F6/DFS/MS/School/2016/NDZ/1205 dated 25/11/2016. The school building was re-inspected by the officer concerned of this department on 18/09/2025 in presence of Mrs. Valsamma Thomas (Associate Director) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 and the school is fit for occupancy class "Educational Building" (Group - B) for Ground plus three upper floors only with effect from 30/09/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed overleaf.

Issued on 30/09/2025 at New Delhi by.


VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
2. The Associate Director, The Saviour's School located at B - 106 (New No.872), New Ashok Nagar, Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. This FSC is issued / valid for Ground plus three upper floors only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. At the time of inspection basement used as store and the terrace of the school building Sealed and Not in use (Undertaking dated 16/09/2025 enclosed).
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhi.govt.nic.in.

INSPECTION REPORT

1	Name & address of the building	The Saviour's School located at B - 106 (New No.872), New Ashok Nagar, Delhi - 110096.		
2	Building is comprised of	Basement (Store), Ground plus three upper floors, Terrace floor - 03 room SPS(Sealed and Not in use), School running on Ground plus three floors only.		
3	Type of occupancy	Educational Building		
4	Type of case	Addition/Alteration		
5	Details of previous FSC	F6/DFS/MS/School/2016/NDZ/1205 dated 25/11/2016		
6	Fire safety directives letter no.	DOE Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	18/09/2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Valsamma Thomas (Associate Director)		
10	Year of construction	1999		
11	Applicant's letter no.	Email dated 20/08/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters.	6.0 meters.	MR
	B Gate width	4.5 meters.	4.5 meters.	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR
	b Basement	01 no.	02 nos.	MR
	B Width of staircases			
	a Upper floor	1.5 meters.	1.18 meter. & 1.10 mtrs	MR (Old accepted)
	b Basement	1.5 meters.	1.20 meter. & 1.10 mtrs	MR (Old accepted)
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

N/15

5. Fire Extinguisher:				
A	Total numbers	08 nos.	08 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtr.	30 mtr.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 liters.	5,000 liters.	MR

15	Exit signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note: - Basement used for store purpose only, school running on Ground + 03 floors only and the terrace floor with 03 rooms (Sealed and Not in use) as per undertaking dated 16/09/2025.

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued by this department vide letter no. F6/DFS/MS/School/NDZ/2025/617 dated 07/08/2025 have been rectified.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2016/NDZ/1205 dated 25/11/2016, renewal under Rule 35 of the Delhi Fire Service rules 2010, is **recommended**.

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO/Laxmi Nagar

D.O/EAST

[Signature]
23/9/2025

C.F.O.

[Signature]
24/9/2025

Principal Director

CFO to *[Signature]*

[Signature]
23/9/25

ADO(LN)

sir. F.T. Letter is put up for sign. Please

CFO

[Signature]
29/9/2025