



FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya Vishwamitra (New SPS) located at Old Seemapuri, Delhi - 110095, comprised of Two Blocks, Block - A & B - Ground plus three upper floors owned/occupied by Sarvodaya Kanya Vidyalaya Vishwamitra have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 23/12/2024 in the presence of Mrs. Poonam Jain (HOS) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. and that the school building is fit for occupancy class B "Educational Building" with effect from 10/01/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 10/01/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Assistant Engineer (E), PWD, Sub Division-4, Edu. Elect. Edn.-1, Rama Road, Zakhira, Delhi.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
3. The Principal, Sarvodaya Kanya Vidyalaya Vishwamitra (New SPS), Old Seemapuri, Delhi - 110095.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/15

INSPECTION REPORT

1	Name & address of the building	Sarvodaya Kanya Vidyalaya Vishwamitra (New SPS), Old Seemapuri, Delhi - 110095.
2	Building is comprised of	Two Blocks, Block - A & B - Ground plus three upper floors.
3	Type of occupancy	Educational Building
4	Type of case	New Case
5	Details of previous FSC	NIL
6	Fire safety directives letter no.	NBC Part-IV
7	Date of inspection	23/12/2024
8	Name of the inspecting officers	Yashwant Singh Meena ADO/Laxmi Nagar
9	Name of the designation of officer from the building side	Mrs. Poonam Jain (HOS)
10	Year of construction	2023 & 2024
11	Applicant's letter no.	Outdoor Diary No. 8728 dated 08/11/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	06 meters.	06 meters	MR
	B Gate width	4.50 meters.	4.50 meters.	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos. in each block	02 nos. in each block	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 meters. in each block	1.80 meters. in each block	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no. in each block	02 no. in each block	MR
	E Width of corridor	1.50 meters. in each block	2.50 meters in each block	MR
	F Door size & No. of Doors	1.20 meters x 02 nos.	1.20 meters x 02 nos.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

3

4/16

Sarvodaya Kanya Vidyalaya Vishwamitra located at Old Seemapuri, Delhi - 110095.

Sarvodaya Kanya Vidyalaya Vishwamitra located at					
5.	Fire Extinguisher:				
	A	Total numbers	24 nos.	28 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 nos. in each blocks	Block A- 02 nos. Block B- 03 nos.	MR
	B	Length of hose reel hose	30 meters	30 meters	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		Required	Provided	MR
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM each block	450 LPM x 02 nos. each block	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

(u)


√

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10, 000 liters in each blocks	10, 000 liters in each blocks	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A	N/A





The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

No file is pending with me before disposal of this case.


 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO/Laxmi Nagar

D.O/EAST


 Dy. C.F.O. (N.D.Z.)
 06/01/2025

 C.F.O.
 6/01/2025

 Director
 7/1/25

 R.T.O.