



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/ 570

Dated: 30/12/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Savor works Coffee and Chocolate (A unit of Savor works Artisans Pvt. Ltd) at Prop. No. 9, Ground and First Floor, Commercial Complex, Masjid Moth, Greater Kailash Part-II, New Delhi-110048

Sir,

This has reference to online MHA ID No. 2024121618074 dated 16/12/2024. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 20/12/2024 with a view to verify status of the fire safety arrangements in the presence of Mr. Raj Singh (Proprietor). During the inspection, the shortcomings observed are as below.

1. The width of the staircases provided are 1.20m & 1.45m respectively against required width of 1.50m each.
2. The required first-aid hose reel not found provided.
3. MOEFA/MCPs not found provided.
4. Terrace pump of 450 LPM discharge capacity, 40m head not provided.
5. Exit signage not found provided.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Authorized Signatory, M/s Savor works Coffee and Chocolate (A unit of Savor works Artisans Pvt. Ltd) at Prop. No. 9, Ground and First Floor, Commercial Complex, Masjid Moth, Greater Kailash Part-II, New Delhi-110048