

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/611

Dated: 04/08/2025

To

M/s Scholars Home International School,  
B-7/164, Phase-IV, Bandh Road,  
Aya Nagar Extension, New Delhi 110047

Sub: Regarding issuance of Fire Safety Certificate in r/o Scholars Home International School, B-7/164, Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi 110047.

Sir,

This has reference with your letter no SHIS/2025/16 dated 02/07/2025 received through outdoor diary no 3352 dated 03/07/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 15/07/2025 in the presence of Mr. Mrs. Chanchal (Principal) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Overhead tank capacity 5,000 ltrs provided against the required capacity 10,000 ltrs.
2. Two temporary rooms are fund constructed at terrace level, which are not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.