C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/WZ/School/2026/ 170 Dated: 28/10/2026

FIRE SAFETY CERTIFICATE

Certified that **The Abhyas School** located at Plot No. 03, Kh. No. 97, Opposite Dominos, Old Kapashera-Najafgarh Road, Kapashera, New Delhi- 110037. building comprised of ground plus one upper floor, owned/occupied by The Abhyas School. The school building was inspected by the officer concerned of this department on dated 09.10.2026.in the presence of Ms. Prem Lata, and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus one upper floor**) is fit for occupancy class B "Educational Building" with effect from 28/10/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 28/10/2026 at New Delhi.

(A.K.Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1 Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
2 The Principal, The Abhyas School located at Plot No. 03, Kh. No. 97, Opposite Dominos, Old Kapashera-Najafgarh Road, Kapashera, New Delhi- 110037

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

MY

INSPECTION REPORT				
1.	Name & address of the building	The Abhyas School at Plot No. 03, Kh. No. 97, Opposite Dominos, Old Kapashera, Najafgarh Road, Kapashera, New Delhi- 110037.		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground plus one upper floor		
4.	Type of Case	New Case		
5.	Details of previous NOC No.	Nil		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	09.10.2026		
8.	Name of the Inspecting Officer	R.K. Yadav, ADO (DWK)		
9.	Name and designation of Officer from the building side	Ms. Prem Lata		
10.	Year of Construction	2019		
11.	Applicant's letter No.	TAS/2026-27/01 dated 18.08.2026		
Sr. No.	**Minimum standards on fire prevention and fire safety U/R 33**	**Requirements as per NBC Part- IV**	**Provided at site**	**Remarks MR/NMR**
1.	**Access of building**			
	• Road width	6.0 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, width, Type & Arrangements of exits**			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.20 m	Provided	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Managements System**			
	• Basement.	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	**Fire Extinguishers**			
	• Total numbers	08 Nos.	Provided	MR
	• Types	ABC &CO_2	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	**First–Aid Hose Reels**			

NS

	• Total numbers on each floor	01 nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	**Automatic fire detection and alarming system.**			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main pump	N/A	N/A	N/A
	➢ Head of main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Staring/Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	Provided	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR
14.	**Captive water storage for firefighting**			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw of connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	**Exit signage**	Required	Provided	MR
16.	**Provision of lifts**			
	➢ Pressurization of Lift Shaft	N/A	N/A	N/A
	➢ Pressurization of lift lobby	N/A	N/A	N/A
	➢ Communication in lift Car	N/A	N/A	N/A
	➢ Fireman's Grounding Switch	N/A	N/A	N/A
	➢ Lift Signage	N/A	N/A	N/A

N/6

17.	**Standby Power Supply**	N/A	N/A	N/A
18.	**Refuge Area**			
	➢ Total area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	➢ Detector system panel	N/A	N/A	N/A
	➢ Flow Switch Panel	N/A	N/A	N/A
	➢ PA System Panel	N/A	N/A	N/A
	➢ Battery backup	N/A	N/A	N/A
	➢ Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection Systems for Protection of Special Risks, if any;**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The school building comprised of ground plus one upper floor only. 07 rooms at ground floor and 02 rooms at first floor (total 09 class rooms).

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

16/10/2026

Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO (SW)

15/x/26

DFO (W2) - On Medical Rest

CFO (HQ)

16/x/26
A.K. MALIK

Pr. DFO CFO to note. 16/x

CFO (HQ)

16/x/26
A.K. MALIK

DDO (HQ-II) 21/x/26

ADO (DWK)

N/7

FT letter is put up for sign please

21/10/2016
(RK YADAV)

CFO

22/10/16
A.K. MALIK

M.S cell