



FIRE SAFETY CERTIFICATE

Certified that the **School of Excellence** located at **Khichripur Village Delhi - 110091**, comprised of **ground plus three upper floors**, (except main hall) owned/occupied by **School of Excellence** was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/1032 dated 20/12/2021. The School building was re-inspected by the officer concerned of this department on 04/03/2025 in presence of Mr. Rajesh (Principal) & Mr. Ranjan Singh (Estate Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" **ground plus three upper floors, except main hall** with effect from 12/03/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 12/03/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

O/C DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.
2. The Principal, School of Excellence located at Khichripur Village Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	School of Excellence located at Khichripur Village Delhi - 110091.		
2	Building is comprised of	Ground plus three upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/1032 dated 20/12/2021		
6	Fire safety directives letter no.	N/A		
7	Date of inspection	04/03/2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Rajesh (Principal) & Mr. Ranjan Singh (Estate Manager)		
10	Year of construction	2016		
11	Applicant's letter no.	Email dated 25/02/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	06 mtrs.	06 mtrs ✓ MR
	B	Gate width	4.5 mtrs.	4.5 mtrs. MR
	C	Width of internal road	N/A	N/A N/A
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	02 no 02 nos. ✓ MR
		b	Basement	N/A N/A N/A
	B	Width of staircases		
		a	Upper floor	1.5 mtrs. each 1.5 mtrs. each ✓ MR
		b	Basement	N/A N/A N/A
	C	Protection of exits		
		a	Fire check door	N/A N/A N/A
		b	Pressurization	N/A N/A N/A
	D	No. of continuous staircases to terrace	02 no.	02 no. ✓ MR
	E	Width of corridor	1.5 mtrs.	1.5 mtrs. ✓ MR
	F	Door size class room	1.0 mtr.	1.0 mtr. MR
3	Compartmentation: ✓			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	N/A	N/A N/A
	C	Fire rating of shaft door	N/A	N/A N/A
	D	Water curtain	N/A	N/A N/A
	E	Fire dampers	N/A	N/A N/A
4	Smoke Management System:			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A

School of Excellence located at Khichripur Village Delhi-110091

5.	Fire Extinguisher:				
	A	Total numbers	20 nos.	24 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 nos.	Provided	MR
	B	Length of hose reel hose	30 mtrs.	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM x 02 nos.	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

N/26

School of Excellence located at Khichripur Village Delhi - 110091

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters.	20,000 liters ✓
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/470 dated 21/07/2024 by this department has been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/1032 dated 20/12/2021, renewal under Rule 35 (6) of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.



Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO/Laxmi Nagar

D.O/EAST/on leave.

DCFO/NDZ

Line
06/08/25

C.F.O.

17/8/2025

Director
10/01/25

ADP/VI

P.T.O