



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 1053

Dated: 22/08/2025

FIRE SAFETY CERTIFICATE

Certified that the School of Excellence, Sector-23, Rohini, Delhi-110085, (School Id-1413342) comprised of Basement + Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/WZ/School/881 dated 11.08.2022. The premises was re-inspected by the officer concerned of this department on 05.08.2025 in the presence of Dr. Ravinder Kumar (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Group B Educational" with effect from 22/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/08/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director of Education, Old Secretariat, Delhi
2. The Principal, School of Excellence, Sector-23, Rohini, Delhi.110085.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : School of Excellence, Sector-23, Rohini, Delhi.110085.
(School Id-1413342)
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Basement + Ground + 03 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2022/WZ/School/881 dated 11.08.2022.
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 05.08.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Dr. Ravinder Kumar (Principal)
9. Year of Construction : 2017
10. Applicant's letter No. : OD No.3236 dated 30.06.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	6.0m	6.0m	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	4.5m -NA-	4.5m -NA-	MR -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	03nos.	03nos.	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	02 & 02 ramp	02 & 02 ramp	MR
	b. Width of staircases	1.5m	2.0m	MR
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m	2.0m	MR
	c. Protection of exits	-NA-	-NA-	-NA-
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	01nos.	Provided	MR
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.0m	1.15m	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan Natural ventilated	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	40nos. ABC/CO2 ISI marked	Provided ABC/CO2 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02nos. 30mm 5m	03nos. Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-

	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	02nos.	03nos.	MR
	• Hose Box	02nos.	03nos.	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	06nos.	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	900lpm	2 x 900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	100,000ltr	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	5 x 5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-

	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F.6/DFS/MS/2022/WZ/School/881** dated **11.08.2022** is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
5/8/25

Signature of the Inspecting Officer

Name Ajay Kumar Sharma

Designation ADO(Rohini)

DO (NW)

24/1-1/12

6/8/2022

[Signature]
05/08/2025

24/8/2022

[Signature]
6/8/2025

CFD

[Signature]
16/8/2025

Principal Director

CFD to Secy.

[Signature]
18/8/25

CFD *[Signature]*

ADO(Rohini)

FT letter is put up for kind
perusal & signature please.

[Signature]
18/8/25

CFD *[Signature]*
21/8/2025

MS