

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2025/ 96

Dated: 06/03/2025

To,

Mr. Mahesh Dutta Sharma,  
House No.B-218,  
Nathupura, Burari,  
Delhi-110084.

**Sub:** Issue of FSC in r/o M/s Scope Social Interaction Centre, located at Shop No. Core-6 Scope, Lodhi Road, Delhi-110033.

Sir,

This is reference to online application no. 2025020401463 dated 15.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **19.02.2025**, in presence of **Mr. S.B Tarey** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of alternate Staircase is 1.50 mtr not provided.
2. The width of gr. floor door is 1.30 mtr against the required width of 1.5 mtr.
3. Automatic sprinkler system in club/restaurant & some compartments area not provided.
4. Addition/alteration found carried in the double height existing area of core 6.
5. Alternate exit staircase is through occupied area of gym.
6. Combustible material plastic decoration found carried out on walls of club area.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I"/MCD Portal and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph, 011-23414000

Copy to:

1. MCD Portal ID-2025020401463 dated 15.02.2025