



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/37

No. F6/DFS/MS/School/SZ/2025/ 312

Dated: 02/05/2025

To

The Principal,
SES, Baba Nebhraj Sr. Sec. School,
Lajpat Nagar-1, New Delhi-110024.

Sub:- Regarding issuance of Fire Safety Certificate in respect of **SES, Baba Nebhraj Sr. Sec. School, Lajpat Nagar-1, New Delhi-110024.**

Sir,

With reference to letter bearing outdoor diary no. 254 dated 04.04.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.04.2025 in the presence of Mr. Naveen Kumar Yajurvedi (ASO) and following shortcomings were observed:-

1. Hose reel found removed.
2. Fire pump found not in auto mode.
3. Terrace Fire Tank capacity of 10,000 liters has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.