



294

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2025/NDZ/ 966

Dated: 08/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Seth Bhagwan Dass Sr. Sec. Public School** located at **30/14B/17, Main Road Maujpur, Delhi- 110053**, comprised of ground, 1st Floor & 2nd Floor, owned/occupied by Seth Bhagwan Dass Sr. Sec. Public School was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/743 dated 07/07/2022. The school building was re-inspected by the officer concerned of this department on 24/07/2025 in the presence of **Mr. Arun Kumar Singh (Manager)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class **“Educational” (Group-B)** with effect from 08/08/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 08/08/2025 at New Delhi by.

[Signature]
6/08/2025

(VIRENDRA SINGH)
2, CHIEF FIRE OFFICER

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. Seth Bhagwan Dass Sr. Sec. Public School located at 30/14B/17, Main Road Maujpur, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for Ground, 1st Floor & 2nd Floor only.
2. Four rooms on terrace should not be used for school purpose in any case.
3. All the means of escape shall be kept free of all type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
7. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Seth Bhagwan Dass Sr. Sec. Public School,
30/14B/17, Main Road Maujpur, Delhi- 110053,
2. Building is comprised of : Ground , 1st floor, 2nd floor & 4 rooms on terrace
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/743 dated 07/07/2022
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 24/07/2025
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Arun Kumar Singh (Manager)
10. Year of Construction : 1988
11. Applicant's letter No : SBDS/2025/590 dated 20/06/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per NBC	Provided at Site	Remarks MR/NMR
01	Access to building			MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr. N/A N/A	10 mtr. N/A N/A	N/A N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 nos.	03 nos.	MR
	<ul style="list-style-type: none"> Upper Floor Basement 	N/A	N/A	N/A
	B. Width of Staircases	1.50 mtr.	1.50 mtr, 0.88 mtr & 0.88	MR
	<ul style="list-style-type: none"> Upper Floor Basement 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A

05.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

2/18

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	5,000 ltr	10,000 ltr	MR
	• Overhead Tank capacity	Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

Note:- School building comprised of ground, 1st floor, 2nd floor & 04 rooms on terrace. Management have given an undertaking that they will not use these 4 rooms on terrace for school purpose and sealed by them (Attached at C-91)

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules. The FSC issued vide letter No. F.6/DFS/MS/School/2022/NDZ/743 dated 07/07/2022 renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
24/07/2025
Signature of the Inspecting Officer
Name : - Deepak Kumar
Designation : - A.D.O (Shd)

DOED Submitted for approval please.

By. C.F.O. (NDZ)

C.F.O.
29/7/2025
Principal Director

Deepak
24/07/25
24/7/2025

CFO to Secy.

CFO/NDZ
24/07/2025
PT. 9