

C-34



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
 आज़ादी का  
 अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2025/WZ/ 283

Dated:- 26/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the SGN Public School, Located at H-243, Kunwar Singh Nagar, Nangloi, New Delhi-110041, comprised of Ground + 01 Upper Floor only, owned/occupied by Sadguru Consciousness Society (Regd.), was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2021/1065 dated 23/12/2021. The said premise was re-inspected by the officer concerned of this department on 10/03/2025 in the presence of Sh. Kunal Swami (Director) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 26/03/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 26/03/2025 at New Delhi by

(Atul Gang)  
 Director  
 Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, SGN Public School, H-243, Kunwar Singh Nagar, Nangloi, New Delhi- 110041,

**Conditions for the validity of fire safety certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

# INSPECTION REPORT

p-20

1. Name and address of the building: **SGN Public School, located at H-243, Kunwar Singh Nagar, Nangloi, New Delhi-110041**
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2021/1065 dated 23/12/2021
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01/03/2011
6. Date of inspection : 10/03/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Kunal Swami (Director)
9. Year of Construction : 2006
10. Applicant's letter No. : email dated 30/01/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per D.O.E. Cr. No. 3298-3398 dated 01/03/2011		Provided at site	Remarks MR/NMR
1.	Access of building	06 m	Provided		MR
	• Road width	4.5 m	Provided		MR
	• Gate width	NA	NA		NA
	• Width of internal road				
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases	02	02		MR
	• Upper floors	NA	NA		NA
	• Basements				
	b. Width of staircases	1.5 m or less & 0.75 m	1.35 m x 1 & 1.15 m x 1		MR
	• Upper floors	NA	NA		NA
	• Basements				
	c. Protection of exits	NA	NA		NA
	• Fire check door	NA	NA		NA
	• Pressurization	01	Provided		MR
	d. No of continuous staircase to terrace	1.5 m	Provided		MR
	e. Width Of Corridor	1.0 m	Provided		MR
	f. Door Size				
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	Required	Natural Ventilation		MR
5.	Fire Extinguishers				
	• Total numbers	08 nos.	Provided		MR
	• Types	ABC & CO <sub>2</sub>	Provided		MR
	• ISI marking	ISI Marked	Provided		MR

0-21

6.	First – Aid Hose Reel			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	NA	Provided	MR
	• Nozzle diameter	NA	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N-22

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as per D.O.E. Circular no. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2021/1065 dated 23/12/2021 is recommended.

Accordingly DFA is prepared for approval & signature please.

*ecr/wr*

*18/05/25*

*18/05/25*  
Aman Kumar Lathar  
ADO (JWP)

13/2025-

*ecr*  
*18/05/2025*  
*Director*  
*18/05/25*

*ecr/wr*

Sir,  
F.S. letter is put-up for your signature 10/

*Director*  
*21/05/25*  
*m*

*18/05/25*  
Aman (JWP)