

c/92

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/GH/129

Dated: 21/03/2025

To

The Manager
M/s Shafaat Guest House, 3908,
Jagat Cinema Street, Jama Masjid,
Delhi.

Sub: Regarding issuance of FSC in r/o M/s Shafaat Guest House, 3908, Jagat Cinema Street, Jama Masjid, Delhi.

Sir,

This has reference to online id no. 2025022702517 dated 27/02/25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 13/03/25 in the presence of Mr. Shafaat Ali and following shortcomings were observed:-

1. Hose reel is not provided each floor.
2. Pump is not auto start provision.
3. Overhead water tank is provided of 4,000 liter against the requirements of 5,000 liter.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.