



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 / Club / WZ / 133

Dated: 20/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **M/s Shalimar Bagh Club** located at **Plot No. 9, B- Block, Shalimar Bagh, New Delhi-110088** comprised of **Basement, Ground plus Two upper floors** was issued FSC by this department vide letter No F6/DFS/MS/WZ/Club/2022/240 dated 30.05.2022. The premise was re-inspected by the officer concerned of this department on 11.03.2025 in the presence of **Sh. Dharmender Pradhan & Sh. T.R. Garg** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy **Assembly (Group-D)** with effect from 20/03/2025 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2025 at New Delhi, by

(Atul Garg
Director
Delhi Fire Service

Copy to :-

1. M/s Shalimar Bagh Club located at Plot No. 9, B- Block, Shalimar Bagh, New Delhi-110088.
2. The Joint Commissioner of Police, Licensing Unit, First floor, PS Defence Colony New Delhi.
3. The DHO, Keshav Puram Zone, Keshavpuram, Delhi- 110035.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The basement shall be used strictly as per the provision of unified building bye laws.

INSPECTION REPORT

1. Name & address of the building : Shalimar Bagh Club located at Plot No. 9, B- Block, Shalimar Bagh, New Delhi- 110088.
2. Type of Occupancy : Assembly (Group-D).
3. Building Comprised of : Basement, Ground plus two upper floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/Club/2022/240 Dated 30/05/2022
6. Fire Safety directives letter No : F6/DFS/MS/BP/2000/913 Dated 25/05/2000
7. Date of inspection : 11/03/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Dharmender Pradhan & Sh. T.R. Garg
10. Year of Construction : 2005 As per N-14
11. Applicant's letter No. : E Mail ID dated 06/03/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Inspection report dated 26/05/2022.	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	5 m	2 × 3.9 m, Provided	MR(old case)
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	02	Provided	MR
	Basements	02	Provided	MR
	Width of staircases			
	Upper Floor	Old case	1.30 m & 0.98 m	MR(old case)
	Basements	Old case	2.90 m, 0.98 m	MR(old case)
	Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	01	Provided	MR
	Width of Corridor	NA	NA	NA
	Door Size	2 m & 1 m	1.66 m & 0.78 m	MR(old case)
3.	Compartmentation			
	Fire check door	Required	Iron gate Provided in basement	MR
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	Required	Exhaust Fan, Provided	MR
	Upper floors	Required	Provided in kitchen	MR
5.	Fire Extinguishers			
	Total numbers	18	Provided	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	Smoke & Heat	Provided	MR
	Location of Main Panel	Ground Floor	Provided	MR
	Location of Repeater Panel	Each Floor	Provided	MR
	Alternate source of power	Required	Provided	MR

	Hooters' Location			MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Required	Provided	MR
	Basement			MR
	Upper Floor	Required	Provided	MR
	Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants	NA	NA	NA
	Size of riser/down-comer	150 mm	Provided	MR
	Number of hydrants per floor	01	Provided	MR
	Hose Box	01	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	Required	Provided	MR
	Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	1620 lpm	Provided	MR
	Head of Main pump	40 m	Provided	MR
	Number of main pumps	01	Provided	MR
	Jockey Pump out put	250 lpm	Provided	MR
	Jockey pump head	40 m	Provided	MR
	Standby Pump out put	1620 lpm	Provided	MR
	Standby Pump Head	40 m	Provided	MR
	Auto Starting/Manual Stopping	Required	Provided	MR
	Pump House Access	Required	Provided	MR
	Terrace level			
	Discharge of pump	NA	NA	NA
	Head of the pump	NA	NA	NA
	Power Supply	NA	NA	NA
	Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	50,000 ltrs	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	12,500 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Running from Ground to Second floor only		
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			

N-41

Detector System Panel	NA	NA	NA
Flow Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/WZ/Club/2022/240 dated 30/05/2022 under rule 37 of Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Dy cfo/wz

17/3/2025

DCFO/...11.28.2022
Dated...17.13/2025

CFP/
17/3/2025
Director/
18/3/25
ADN/ANV

8m, FT letter in put for sign stamp

19/3/25

Director/...