



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/Indl./ 257

Dated: 06/06/2025

To,

Sh. Hitesh Bagwani,
M/s Shama Cosmetics,
E-228, Sector-4, Bawana Industrial Area,
Delhi- 110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Shama Cosmetics located at E-228, Sector-4, Bawana Industrial Area, Delhi- 110039.

Sir,

This has reference to your letter no. nil received through outdoor diary no. 846 dated 22/04/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 22.05.2025 to see the compliance of the requisite fire safety measures. Sh. Hitesh Bagwani was present at the time of inspection.


During the course of inspection it was observed that the industrial building is comprised of Basement, Ground, Mezzanine and First Floor. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. Staircases are not segregated as marked in building plan.
2. Fire check doors found not provided as marked in building plan.
3. Smoke management system found not provided in basement.
4. Sprinkles found not provided in left out area in basement and in mezzanine floor.
5. Terrace level pump found provided but not functional.
6. Overhead tank of 10,000 ltrs capacity found provided against the requirement of 20,000 ltrs.
7. Floor level signage and exit signage are not provided.

Keeping in view of above shortcomings Fire Safety Certificate is not considered at this stage and rejected. You are advised to rectify the above-mentioned shortcomings for further consideration in this matter. Till such time occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at your risk and responsibility due to any mishap/ loss of life in the building.

Copy to:-
1. Sh. K.R. Chawla, Dy. Drugs Controller/ Licensing Authority, Drugs Control Department,
F-17, Karkardooma, Delhi- 110032.

Yours Faithfully


5/6/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

