



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/577

Dated: 04/07/2025

To,

The Principal,  
Shankar Public School,  
Main Road, Mandawali,  
Delhi - 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Shankar Public School located at Main Road, Mandawali, Delhi - 110092.**

Sir,

This has a reference to your Outdoor Diary No. 2581 dated 10/06/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24/06/2025 in the presence of Mrs. Rakhee Rawat (Head Mistress) and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Terrace level fire pump of capacity 450 LPM found removed.
3. Overhead tank of capacity 10,000 liters not provided.
4. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

**Copy to: -**

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.