

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 1237

Dated: 08/10/25

FIRE SAFETY CERTIFICATE

Certified that the Shanti Ideal Convent Public School located at Jai Vihar, Phase- III, Najafgarh, New Delhi- 110043, building comprised of ground plus two upper floors, owned/occupied by Shanti Ideal Convent public School. The school building was inspected by the officer concerned of this department on dated 26.09.2025 in the presence of Sh. Ravi Sharma (Manager), and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (ground plus two upper floors) is fit for occupancy class B "Educational Building" with effect from 08/10/25 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 08/10/25 at New Delhi.


(A.K. Malik)

Dy. Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.
2. The Manager, Shanti Ideal Convent Public School located at Jai Vihar, Phase- III, Najafgarh, New Delhi- 110043.

Conditions for validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Shanti Ideal Convent School at Jai Vihar, Phase- III, Najafgarh, New Delhi- 110043.
2. Building is comprised of : Ground plus two upper floor
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous FSC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 26.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Ravi Sharma (Manager)
10. Year of Construction : Before- 2010
11. Applicant's letter No. : SICPS- 01/2025 dated 05.08.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	06 m (Back Side) Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 nos. N/A	03 nos. & 01 ramp N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m each N/A	1.0, 1.50 & 1.40 to 1.50 m, 01 ramp (1.40 m) N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 No. 30 m 5 mm	Provided Provided Provided	MR MR MR


7.	Automatic fire detection and alarming system			N/A	N/A
	• Type of detectors	N/A		N/A	N/A
	• Location of Main Panel	N/A		N/A	N/A
	• Location of Repeater Panel	N/A		N/A	N/A
	• Alternate source of power	N/A		N/A	N/A
	• Hooters' Location	N/A		N/A	N/A
8.	MOEFA	Required	Provided		MR
9.	Public Address System				
10.	Automatic Sprinkler System				
	• Basement	N/A	N/A		N/A
	• Ground Floor	N/A	N/A		N/A
	• Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	• Size of riser/down-comer	N/A	N/A		N/A
	• Number of hydrants per floor	N/A	N/A		N/A
	• Hose Box	N/A	N/A		N/A
12.	Yard Hydrants				
	• Total number of hydrants	N/A	N/A		N/A
	• Hose Box	N/A	N/A		N/A
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A		N/A
	➤ Head of Main pump	N/A	N/A		N/A
	➤ Number of main pumps	N/A	N/A		N/A
	➤ Jockey Pump out put	N/A	N/A		N/A
	➤ Jockey pump head	N/A	N/A		N/A
	➤ Standby Pump out put	N/A	N/A		N/A
	➤ Standby Pump Head	N/A	N/A		N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A		N/A
	➤ Pump House Access	N/A	N/A		N/A
	• Terrace level				
	➤ Discharge of pump	450 LPM	Provided		MR
	➤ Head of the pump	40 M	Provided		MR
	➤ Power Supply	Required	Provided		MR
	➤ Auto Starting of pump	Required	Provided		MR
14.	Captive Water Storage for fire-fighting				
	• Underground tank capacity	N/A	N/A		N/A
	➤ Draw-off connection	N/A	N/A		N/A
	➤ Fire service inlet	N/A	N/A		N/A
	➤ Access to tank	N/A	N/A		N/A
	• Overhead Tank capacity	10,000 Ltrs	Provided		MR
15.	Exit Signage.	Required	Provided		MR
16.	Provision of Lifts. (No Lift)				
	• Pressurization of Lift Shaft	N/A	N/A		N/A
	• Pressurization of Lift lobby	N/A	N/A		N/A
	• Communication In lift Car	N/A	N/A		N/A
	• Fireman's Grounding Switch	N/A	N/A		N/A
	• Lift Signage	N/A	N/A		N/A


		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were test checked and found not functional at the time of inspection.

Note: - As per undertaking submitted by school management (placed at C-41), that the back lane is 6.0 vide (20 feet) road as mentioned in the land certificate and GPA from north and south direction (placed at C- 33) and found all the obstruction removed and a gate is also provided for students. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/SZ/2024/40 dated 01.02.2024 have been rectified.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, **it's recommended to grant Fire Safety Certificate.**



 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

DO (South West) 
 29/9/25


 29/9/2025

Principal Director

By C.S. to S.D.M.



 20/09/25

F.T. please.

 (S.D.)


 1/10/2024
 A.K. Malik

Ad (SW)


 A.D. R.K. Yadav

PTO