



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 162

Dated: 09/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Shanti Niwas Guest House at Prop. No. 159, Kucha Ghani Ram, Chandni Chowk, New Delhi-110006

Sir,

Please refer to online (etl.mcdonline.nic.in) ID. 2025032104239 dated 25/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 03/04/2025 in the presence of Sh. Vaibhav Soni (Owner) of the guest house and the shortcomings observed are as below.

1. First-Aid hose-reel provided found non-functional.
2. Terrace level fire pump was not on auto mode.
3. Capacity of overhead water tank exclusive for firefighting found less than 5,000 liters.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety measures/certificate shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Authorized Signatory M/s Shanti Niwas Guest House at Prop. No. 159, Kucha Ghani Ram, Chandni Chowk, New Delhi-110006