

d/13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2025/ 823  
To

Dated: 20/11/2025

The Principal,  
Sharda Devi Sanskrit Vidyapeeth,  
Darya Ganj, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Sharda Devi Sanskrit Vidyapeeth, Darya Ganj, Delhi - 110002.**

Sir,

This has reference to your letter No. SDSV/2025/421 dated 17.09.2025 received in this department on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 04.11.2025 in the presence of Mr. Vijay Prashad (UDC) and observed that the building is comprised of ground + 04 upper floors, ground floor (temple), 1<sup>st</sup> floor (other office), 2<sup>nd</sup> floor (classroom + hostels), 3<sup>rd</sup> & 4<sup>th</sup> floor (class room) and have complied the shortcomings issued vide letter no. F6/DFS/MS/NDZ/School/2025/570 dated 03.07.2025 except following which still exists.

1. The school is not accessible to fire engines as approach road width is less than 06 mtr.

In view of the above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

/

  
19/11/25

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.