

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2025/119

Dated: 24/03/2025

To

Ms. Rashmi Bhardwaj, Delhi Metro Rail Corporation Ltd., 25, Ashoka Road, Near Patel Nagar Chowk Metro Station, New Delhi-110001

Sub: Examination of building plans from fire & life safety point of view in r/o Shastri Park Depot (Extension of the Workshop and PIT Wheel Lathe) Expansion.

Sir,

Please refer your online building plans ID No. DMRC/Fire/161/2025/02/407 dated 27.02.2025 on the subject cited above. In this connection, this is to inform you that the matter has been examined and observed that the shortcomings issued vide this office letter No. F.6/DFS/MS/BP/2024/453 dated 16.08.2024 (Copy enclosed) are not yet complied in totality.

In view of the above, the case is rejected.

Yours faithfully,

IRECTOR

0 5



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

र्गाडीक अमृत महोत्सव

No. F.6/DFS/MS/BP/2024/453

Dated: 16/08/2024

To,

The Chief Architect DMRC, Metro Bhawan Barakhamba Lane Connaught place New Delhi-110001.

Sub: Examination of building plans from fire & life safety point of view in r/o Extension of Workshop and Pit Wheel Lathe at Shastri Park Depot, Delhi.

Sir,

Please refer your online building plans ID No. DMRC/Fire/161/2024/07/376 dated 22/07/2024 on the subject cited above. In this connection, this is to inform you that the referred building plans in r/o Extension of Workshop and Pit Wheel Lathe at Shastri Park Depot, Delhi have been scrutinized by this department from fire and life safety point of view and following shortcomings are observed: -

- 1. Six mtr. wide approach road is not clearly marked on building plans as per clause 8.2 of UBBL-2016.
- 2. Exit doors are not properly marked on building plans.

In view of the above, the case is rejected.

Yours faithfully,

DIRECTOR

011 - 23414000

@ e 5