

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/231

Dated: 06./05./2025

FIRE SAFETY CERTIFICATE

Certified that the **"SHAURYA" CRPF Officers Institute** located at **Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -110070** comprised of Basement, Ground plus One Upper Floor owned/occupied by Central Reserve Police Force, Govt. of India was issued FSC by this department vide letter No. F.6/DFS/MS/2022/SZ/42 dated 28-01-2022. The premises was re-inspected by officers concerned of this department on 28/04/2025 in the presence of Mr. Shivkant (Inspector/GD) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Class **Assembly Building** as above with effect from 06/05/2025 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 06/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Mr. Alok Kumar Shrivastava /PMG "SHAURYA" CRPF Officers Institute located at Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -110070.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	SHAURYA "CRPF Officers Institute at Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -70		
2	Type of Occupancy	Assembly Building		
3	Building Comprised of	Basement, Ground + 01 upper floor, Block 2 Not Constructed		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2022/SZ/42 dated 28-01-2022		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2003/1524 dated 09.07.2003		
7	Date of Inspection	28/04/2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shivkant (Inspector/GD)		
10	Year of construction	1999		
11	Applicant letter No.	Outdoor diary no 346 dated 08-04-2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	05 mtr	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 + 01 ramp	Provided	MR
	➤ Basement floor.	04 + 01 ramp	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 m	1.50 m each & 1.2 m ramp	MR
	➤ Basement floor	1.50 m / 1.25m	1.50m x 03 , 1.25 m & 5.9m ramp	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 No	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size (Exits in hall)	1.5m	1.50 m (04no in auditorium)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	34 Nos	MR
	• Types	ISI marked	Co2, ABC & DCP	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR

17/20

	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat/Smoke/Beam	MR
	• Location of Main Panel	-NA-	Ground floor	-NA-
	• Location of Repeater Panel	Required	Fire control room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	-NA-	All Areas	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors.	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants.			
	• Size of Riser/Down-corer	150 mm	Provided	MR
	• Number of Hydrant per floor	02 Nos	Provided	MR
	• Hose box.	02 Nos	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	Required	Provided	MR
	• Hose box.	Required	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2850 LPM	Provided	MR
	➤ Head of main pump.	70 M	Provided	MR
	➤ Number of main pumps.	01 No	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70 M	Provided	MR
	➤ Standby Pump output.	2850 LPM	Provided	MR
	➤ Standby Pump head.	70 M	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	2,00,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room.	Required	Provided	MR
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	Required	Provided	MR
	• PA system panel.	Required	Provided	MR
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/2022/SZ/42 dated 28-01-2022 renewal under rule 35(6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Signature] 30/4/25

CFD (PDS) *[Signature]*
01/5/2025

Director *[Signature]*
15/5

[Signature]

As approved, F-4 letter is put up for your signature

[Signature]
[Signature]

[Signature]
5/5