

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/GH/169 To,

Mr. Devinder Singh, House No.A-5, Mansarover Garden, New Delhi-110015.

Sub: Issue of FSC in r/o M/s Shbad Dx. Guest House located at 31, Ram Nagar, Pahar Ganj, New Delhi-Sir,

This is reference to online application no.2025032204309 dated 22.03.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 02.04.2025, in presence of Mr. Devinder Singh to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

- 1. Terrace fire pumps were not found in auto mode and leakage found in packing of pump casing.
- 2. Manually operated electric fire alarm is provided but not functional.
- 3. CO detector system provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http:/ /www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

Copy To:-

1. MCD Portal Id- 2025032204309 dated 22.03.2025.