

C/29

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2025/NDZ/ 762

Dated: 10/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Shemrock Waves School (Shiva Shiksha Samiti) located at R-Block, Dilshad Garden, Delhi-110095, owned / occupied by Shiva Shiksha Samiti, was earlier issued Fire Safety Certificate from this department vide letter No. F6/DFS/MS/2006/1633 dated 18/07/2006 for **Ground and first floor only. Building now comprised of Ground plus two upper floors** owned / occupied by Shiva Shiksha Samiti. The premises was inspected by the officers concerned of this department on 20/05/2025 in the presence of Mr. Tej Pal Singh (Manager) and found that all the fire prevention and Fire Safety Arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the premises is fit for occupancy class "Educational" (Group-B) for **Ground plus two upper floors** with effect from 10/06/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below.

Issued on 10/06/2025 at New Delhi by

10/06/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
o/c 10/06/2025

Copy to :-

1. The Manager, Shemrock Waves School (Shiva Shiksha Samiti), R-Block, Dilshad Garden, Delhi-95.
2. The Director of Education, MCD, Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi-92.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Shemrock Waves (Shiva Shiksha Samiti),
R-Block, Dilshad Garden, Delhi-110095**
2. Building is comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : New Case (Addition/Alteration)
5. Details of Previous NOC/FSC : F.6/MS/DFS/2006/1633 Dated 18/07/2006 (For G+1)
6. Fire Safety directive letter No : F.6/DFS/MS/BP/2011/633 dated 08/04/2011
7. Date of Inspection : 28/05/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar & DO, A.K. Jaiswal
9. Name and designation of Officer
from the building side : Sh. Tej Pal Singh (Manager)
10. Year of Construction : 2008 & 2017
11. Applicant's letter No : Outdoor Diary No. 1043 dated 25/04/2025

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 mtr.	Provided	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr & 0.90 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos	02 nos.	MR
		1.50 mtr.	Provided	MR
	e. Width of Corridor	01 mtr.	01 mtr.	MR
	f. Door Size			
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door			
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	06 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	• Total numbers on each floor	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the Pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under rule, the FSC was issued vide letter No. F.6/MS/DFS/2006/1633 dated 18/07/2006 (G+1). It is recommended to grant Fire Safety Certificate for ground to second floor under rule 35 of the Delhi Fire Service Rules 2010.

Deepak
28/05/2025
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

A.K. Jaiswal
28/05/2025
Signature of the Inspecting Officer
Name :- A.K. Jaiswal
Designation :- D.O (ED)

~~DCFO (NDZ)~~
king
02/06/25
C.F.O/
king
31/6/2025

~~DO (ED)~~
Sir,
As Approved, F. T. is put up for signature pl.

C.F.O/
king
31/6/2025
A.K. Jaiswal
06/06/2025

MS Cell