

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6/DFS/MS/EH/2025/SZ/BNQT/44

Dated. 29/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s SHER E DIL** located at **B-7 Ground Floor**, Shankar Garden Vikas Puri, New Delhi 110018 in the building comprised of Basement, Ground plus Three upper floors owned/occupied Ms. Sandhya Oberoi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/BNQT/2022/SZ/64 dated 05/12/2022 for Victoria Banquet hall. The restaurant premise was re-inspected by the officer concerned of this department on 09/07/2025 in the presence of the Mr. Himanshu (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at Ground floor only)** and **validity upto 31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/07/2025 at New Delhi by


(VIRENDRA SINGH)
**CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to: -

1. The Addl. Commissioner of Police, Lic/Branch, 1st Floor PS Defence Colony New Delhi 110049 (Ref. MCD Portal ID 2025062010333 dated 20/06/2025)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s SHER E DIL located at B-7 GF Shankar Garden Vikas Puri, New Delhi 110018.		
2	Type of Occupancy	Group-D Assembly Building. (Eating House)		
3	Building Comprised of	Basement Ground plus three upper floors but (Rest. running at Ground floor only)		
4	Type of Case	New Case		
5	Details of Previous NOC	F6/DFS/MS/BNQT/2022/SZ/64 dated 05/12/2022 for Banquet		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	09/07/2025		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar ADO/BCP		
9	Name & Designation of Officers from the building side	Mr. Himanshu (Manager)		
10	Year of construction	2010 as per MCD Portal ID		
11	Applicant letter No.	MCD Portal ID 2025062010333 dated 20/06/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL 2016 /NBC Part IV	Provided at Site	Remarks MR/NMR
1	Access to Building.	09 mtr	Provided	MR
	• Road width	4.50 mtr	Direct accessible	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2	Number, width, type & arrangement of exits.	Restaurant at Ground floor only		
	a) Number of Staircase	N/A	N/A	N/A
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.			
	b) Width of Staircase	N/A	N/A	N/A
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor			
	c) Protection of exits	N/A	N/A	N/A
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	1.50 mtr each	1.50 mtr & 2 mtr	MR
	f) Door size			
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	NA	N/A	N/A
	• Basement	NA	N/A	N/A
	• Ground floor /Rest. area			
5	Fire Extinguishers.	06 No's	06 Nos	MR
	• Total numbers	ABC/CO ₂	ABC & CO ₂	MR
	• Types	ISI marked	Provided	MR
	• ISI Marking			
6	First Aid Hose Reels.	01 Nos	Provided	MR
	• Total numbers on each floor.	30m	Provided	MR
	• Length of hose-reel hose.			

	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground/ upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	01 No	Provided	MR
	• Hose box.	01 No	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	30m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			

m/39

	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the management has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 100 dated 04/06/2025.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO/BCP

DO (SW)

11/7/25

CFD

11/7/2025

Director

ADP/BCP

As approved, F.T. letter is put up for your signature

CFD/HQ

Principal Director

ADP/BCP

11/7/2025

CFD may issue the letter at HQ level.

11/7/2025

25/7/25