



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/SW/2025/BNQT/100

Dated: 04/06/2025

To,

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi


Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Sher E Dil at B-7, Shankar Garden, Vikaspuri, Delhi-110018.

Sir,

With reference to online application No. 2025050808112 dated 09.05.2025 on the subject cited above, it is informed that the premises was inspected by the officers concerned of this department on 23.05.2025 in the presence of Mr. Himanshu (Manager) and it was observed that this department has already issued shortcomings vide letter no. F.6/DFS/MS/EH/SZ/2025/BNQT/74 dated 06.05.2025 which are not complied as yet (Copy of the same is enclosed for your reference).

In view of the above issuance of Fire Safety Certificate cannot be considered at this stage. Therefore, you are advised to apply through the said online portal for further consideration in the matter after rectifying all the shortcomings.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer

Copy to:-

The Manager,
M/s Sher E Dil,
B-7, Shankar Garden, Vikaspuri,
Delhi-110018.

GOVERNMENT OF NATIONAL CAPITAL
HEADQUARTERS: DELHI FIRE SERVICE

RY OF DELHI
DELHI- 110001

No F6/DFS/MS/EH/SZ/2025/BNOT/74

Dated: 06/05/2025

To
The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s SHER E DIL located at B-7, GF,
Shankar Garden, Vikas Puri, New Delhi - 110018.

Sir,

This has reference to MCD online application ID No. 2025041206275 dated 12.04.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.04.2025 in presence of Mr. Himanshu (Manager) and it was observed that building is comprised of Basement + ground + 03 upper floors but restaurant at ground floor only. During inspection, following shortcomings were observed:

1. Exits are blocked by store material & sofa.
2. First aid hose reel provided but not functional.
3. MOEFA provided but not functional.
4. Down comer system provided but not functional.
5. Fire pump provided but not functional & not in auto start mode.
6. Over head water storage tank capacity of 10,000 liters provided against the requirement of 20,000 ltrs.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 01123414000
06/05/25

Copy to:-

The Manager,
M/s SHER E DIL at B-7, GF, Shankar Garden, Vikas Puri, New Delhi - 110018.