

C-140

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/SZ/2025/ BNOT/74

Dated: 06/05/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s SHER E DIL located at B-7, GF, Shankar Garden, Vikas Puri, New Delhi - 110018.

Sir,

This has reference to MCD online application ID No. 2025041206275 dated 12.04.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.04.2025 in presence of Mr. Himanshu (Manager) and it was observed that building is comprised of Basement + ground + 03 upper floors but restaurant at ground floor only. During inspection, following shortcomings were observed:

1. Exits are blocked by store material & sofa.
2. First aid hose reel provided but not functional.
3. MOEFA provided but not functional.
4. Down comer system provided but not functional.
5. Fire pump provided but not functional & not in auto start mode.
6. Over head water storage tank capacity of 10,000 liters provided against the requirement of 20,000 ltrs.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 01123414000
o/c
01/05
115

Copy to:-

The Manager,
M/s SHER E DIL at B-7, GF, Shankar Garden, Vikas Puri, New Delhi - 110018.