

c - 30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2025/1050

Dated: 22/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Shri Guru Harkrishan Model School Located at D- Block, Tagore Garden Extn New Delhi-110027, (School ID:-1515119), comprised of ground plus two upper floors, owned/occupier by Shri Guru Harkrishan Model School, was issued FSC vide letter No F6/DFS/MS/WZ/School/2022/840 dated 02/08/2022. The premises was re - inspected by the officer concerned by this department on 05/08/2025 in the presence of Sh. Jay Prakash (Vice-Principal) and observed that the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE Circular No. 3298-3398 dated 01/03/2011 and the building/ premises is fit for occupancy class "Educational" (Group -B) (For ground plus two upper floors) with effect from 22/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 22/08/2025 at New Delhi.


21/8/2025
Virendra Singh
Chief Fire Officer

Copy to:

1. The Director, Directorate of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.
2. The Principal/Incharge, Shri Guru Harkrishan Model School at D- Block, Tagore Garden Extn New Delhi-110027. Email: sgms_1978@yahoo.com

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The second staircase shall remain open at all time, if it is closed FSC shall be null &

27/10

INSPECTION REPORT

| | | |
|-----|---|--|
| 1. | Name & address of the building | Sri Guru Harkrishan Model School Located at D- Block, Tagore Garden Extn., New Delhi-110027. (School ID:- 1515119) |
| 2. | Type of Occupancy | Educational (Ground+ 2 Upper Floors) |
| 3. | Type of Case | Renewal |
| 4. | Details of previous NOC | F6/DFS/MS/WZ/School/2022/840 dated 02/08/2022 |
| 5. | Fire Safety directives letter No | DOE 3298-3398 dated 01/03/2011 |
| 6. | Date of inspection | 05/08/2025 |
| 7. | Name of the Inspecting Officers | Sarabjeet Singh ADO (MN) |
| 8. | Name and designation of officers from the building side | Sh. Jay Prakash (Vice -Principal) |
| 9. | Year of Construction | 1979 (As per previous Inspection Report dated 15/07/2022) |
| 10. | Applicant's letter No. | Letter No. SGHMS/5-14/2025-26/132 dated 21/07/2025. |

The said school is running at ground and two upper floors, in a building is comprised of ground + 02 upper floors, was already issued FSC vide letter No. F6/DFS/MS/WZ/School/2022/840 dated 02/08/2022.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | As per Rule 35 (6) DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|--------|---|----------------------------------|-------------------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 6 mts | Provided 6 mts | MR |
| | • Gate width | 5 mts | Directly accessible from road | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50 m | 1X1.30m , 1X1.10m | MR (old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | 1.5 m | 1.55m Provided | MR |
| | f. Door Size | 1.0 m | Varies from 0.80m to 1.0m | MR(old case) |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 09 nos. | Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |

| | | | | |
|----|--|------------|----------|----|
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 01 | Provided | MR |
| | • Length of hose reel hose | 30 mts | Provided | MR |
| | • Nozzle diameter | 05 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/ Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 LPM | Provided | MR |
| | ➤ Head of the pump | 40 m | Provided | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 lts | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|---|----|----|----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | NA | NA | NA |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | NA | NA | NA |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/School/2022/840 dated 02/08/2022, **renewal under DOE circular No. 3298-3398 dated 01/03/2011 is recommended.**

[Signature]
07/8/2025
Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

[Signature]
Dy.CFO (WZ)

FOI...745 WP
dated...7/8/2025

[Signature]
7/8/2025

[Signature]
16/8/2025

[Signature]
Principal Director

[Signature]
CFO to Sarabjeet Singh

[Signature]
20/8/2025

[Signature]
ADO (MN)

P. 70