



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/School/ 339

Dated: 06/05/2025

To,  
The Principal,  
Shri Tula Ram Public School,  
Aman Vihar,  
Delhi-110086.

**Sub:** Issue of FSC in r/o Shri Tula Ram Public School, Aman Vihar, Delhi-86.

Sir,  
Kindly refer to online e-mail dated 03.03.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 22.04.2025, in presence of **Mr. Durdesh** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Internal hydrants found removed.
2. Hose reel provided but not functional.
3. Terrace Fire pump with capacity of 450 LPM found removed.
4. Exit signage not provided.
5. Over Head water captive tank of 10,000 ltrs not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

OK  
dy