

C-94

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 236

Dated: 16.10.2025

To,

The Manager,
M/s Shiv Guest House,
3494, Dariba Pan, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Shiv Guest House, 3494, Dariba Pan, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2025042407063 dated 24/04/25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 26/12/24 in the presence of Manager and following shortcomings were observed:

1. Smoke management system is not provided as per gazette notification dated 27.05.2019.
2. Pump not start in auto mode provision.
3. PA system found nonfunctional.

In view of above e, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

Addl. Commissioner of Police (Lic), 1st floor, Defence Colony Police Station, New Delhi.