



c26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/NZ/2026/ 755

Dated: - 05/08/2026

To,

Sh. Sandeep,
M/s Shiv Nath Rai Sumer Chand Confectioner Pvt. Ltd.,
Shop No. 5, Ground Floor, Vaishali, Pitampura,
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Shiv Nath Rai Sumer Chand Confectioner Pvt. Ltd. located at Shop No. 5, Ground Floor, Vaishali, Pitampura, Delhi- 110034.
Sir,

This has reference to online application received through MCD portal vide ID-2026070309526 dated 06.07.2026 on the subject cited above. Above said eating house running at ground floor of a building comprised of Basement, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department on 21.07.2026 in presence of Mr. Aditya to check the fire safety measures provided in the building.

During the course of inspection, it has been observed that fire safety arrangements such as fire extinguishers found provided, However the following shortcomings have been observed: -

- 1 Basement floor is not compartmentalized/ segregated providing fire check door.
- 2 The width of exits is 1.66 m & 0.90 m instead requirements of 1.5 m each.
- 3 Overhead water Tank of 10,000 ltrs capacity provided against the requirement of 20,000 ltrs capacity.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MCD portal as and when site is ready for inspection.

Yours faithfully


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 9th floor, Civic Centre, Minto Road, New Delhi-110002. (Ref: MCD Portal ID No. 2026070309526)