



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/5  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/176

Dated: 26/03/2025

To,

The Principal,  
Shiv Shakti Public School,  
90, Lok Vihar Phase - IV,  
Shiv Vihar,  
Delhi - 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Shiv Shakti Public School located at 90, Lok Vihar Phase - IV, Shiv Vihar, Delhi - 110094.**

Sir,

This has a reference to your outdoor dairy no.12871 dated 24/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/03/2025 in the presence of Mr. Ram Mehar (Head Master) and observed that building comprised of ground plus two upper floors.

**Following shortcomings were observed during time of inspection:**

1. Two staircase of width 1.08 meter & 0.93 meter are provided against requirements of 1.50 meter.
2. All fire extinguishers found empty.
3. First-Aid-Hose Reel provided but found not functional.
4. MOEFA not provided.
5. Fire pump capacity of 220 LPM provided against requirement of 450 LPM.
6. Over head water storage tank of capacity 5,000 ltr. provided against requirement of 10,000 ltr.
7. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.